

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-1288:109 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Gamewell, 60 Pleasant Street, Ashland, MA 01721
Contact: *Ray Wood (508) 231-1400 Fax (508) 231-0900

DESIGN: FLEX ALERT. An audio control unit adjunct to be used in conjunction with a listed compatible fire alarm control unit to provide tone signals or voice communication capability. The adjunct provides its own alarm tone over the speakers when actuated from auxiliary zone alarm contacts of a fire alarm control unit. The alarm speaker circuit is power limited. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an audio evacuation control unit adjunct to a separately listed compatible fire alarm control unit.

NOTE: Formerly 6911-0064:057

*Rev. 06-11-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager